

TAMIL NADU FIRE & RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE. No: 99/V / AVD / 2023

Avadi Fire & Rescue Service Station

Date: 11.02.2023.

Sub: Fire & Rescue Services Department- Avadi Fire & Rescue Services Station for purpose no objection certificate - Reg.

Ref: 1. GO/MS 122 / Dept. of School Education (2), Dated 14.09.2004.
2. GO/MS 123 / Dept. of School Education (2), Dated 14.09.2004.
3. Date of Requisition Letter from Correspondent, VGN Chinmaya Vidyalaya 09.02.2023.

Based on the Gov't Order mentioned above and the requisition letter given by the VGN Chinmaya Vidyalaya at Sekkadu Main Road, Avadi, Chennai - 600071, Tamil Nadu the building premises comprises of G + 3 owned / occupied by VGN CHINMAYA VIDYALAYA have complied with the Fire Service Rules, and verified on 10.02.2023 in the presence of Sri.Rajkumar Devarajan, Correspondent and that the school is granted NOC for a period of one year from 11.02.2023 to 10.02.2024 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER (I/C) FIRE & RESCUE SERVICES, K. BAKTHAVATCHALAM ON 10.02.2023.

CONDITIONS

1. This License is valid for ONE YEAR month from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures and insisted.
 - a) Building Occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code -2005.



- b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid failing of children.
- c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms shall have to be limited 45 students.
- d) Periodical maintenance and care should be taken to maintain all fire protection equipment's.
- e) Mock drill has to be conducted at regular intervals in consultation with the Divisional Officer, Fire and Rescue Services, Chennai City Central Division Kilpauk.
- f) The classrooms should always be in the ground floor up to 3rd Standards.
- g) The class rooms doors/windows should be made of either non-combustible material or materials with high fire-resistance rating.
- h) The classrooms doors/windows shall always open outwards.
- i) The classrooms doors/windows shutter when opened should not obstruct movement along the exit or escape route.
- j) A Class room shall have two entrances. One door with opening towards the teachers end the other door on the classroom with only a simple latch/lower bolt arrangement for locking from outside.
- k) The school shall have proper evacuation of Plan of action to rescue the children any emergency in the school premises.

If there is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



Handwritten signature
11/2/23
STATION OFFICER
FIRE & RESCUE SERVICE STATION
AVADI, CHENNAI - 600 054.

To
Sri. Rajkumar Devarajan, Correspondent,
VGN CHINMAYA VIDYALAYA,
Sekkadu Main Road,
Avadi, Chennai - 600 071.

